



TEST REPORT

Report No. : GR:GL:6210020715

DATE : 15-12-06

JOE No. : 621107064

Control No.:6215021727

SAMPLE NOT DRAWN BY LABORATORY

SAMPLE SUBMITTED AND IDENTIFIED BY SUPPLIER AS : EVAPORATIVE COOLING PAD

COMPANY NAME DESICCANT ROTORS INTERNATIONAL PVT. LTD.
ADDRESS 100-101,UDYOG VIHAR-IV
CITY GURGAON-122015
SAMPLING METHOD N.A.
SAMPLE DESCRIPTION Evaporative Cooling Pad
COLOUR DEEP BROWN
ARTICLE/REF. NO. 1
SAMPLE RECD ON 09-12-2006
TEST START DATE 09-12-06
TEST END DATE 15-12-06

TESTS	PROTOCOL	RESULT
CADMIUM	USEPA 3050 B / USEPA 3051 A	ND(D.L.1ppm)
LEAD	USEPA 3050 B / USEPA 3051 A	4.48ppm
MERCURY	USEPA 3050 B / USEPA 3051 A	ND(D.L.0.5ppm)
HEXAVALENT CHROMIUM-(Cr-VI)	USEPA 3060 A	ND(D.L.1ppm)
POLYBROMINATED BIPHENYLS (PBBs)	USEPA 3540 C	
Monobromobiphenyl		ND(D.L.5ppm)
Dibromobiphenyl		ND(D.L.5ppm)
Tribromobiphenyl		ND(D.L.5ppm)
Tetrabromobiphenyl		ND(D.L.5ppm)
Pentabromobiphenyl		ND(D.L.5ppm)
Hexabromobiphenyl		ND(D.L.5ppm)
Heptabromobiphenyl		ND(D.L.5ppm)
Octabromobiphenyl		ND(D.L.5ppm)
Nonabromobiphenyl		ND(D.L.5ppm)
Decabromobiphenyl		ND(D.L.5ppm)
POLYBROMINATED DIPHENYLEETHERS (PBDEs)	USEPA 3540 C	
Monobromodiphenyl ether		ND(D.L.5ppm)
Dibromodiphenyl ether		ND(D.L.5ppm)

This document is issued by the company subject to its general conditions of service printed overleaf or available on request and accessible at www.sgs.com. Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. Unless otherwise stated: (A) the results shown in this document refer only to the sample(s) tested and (B) such sample(s) are retained for 30 days only. This document cannot be reproduced except in full, without prior approval of the company. Any unauthorized alteration, forgery or falsification of the content or appearance of this report is unlawful and offenders may be prosecuted to the fullest extent of the law. The information stated in this report (or certificate) is derived from the results of inspection or testing procedures carried out in accordance with the instructions of our client, and/or our assessment of such results on the basis on any technical standards, trade custom or practice, or other circumstances which should in our professional opinion to be taken into account.

SGS India Pvt. Ltd. | Laboratory, 250, Udyog Vihar, Phase IV, Gurgaon - 122015, Haryana (India) Phone : +91-124-2399990 - 98 , Fax : 2399765.

Regd & Corp. Off : SGS House, 4B, A.S. Marg, Vikhroli (West), Mumbai-400083. Tel : (022) 25798421 to 28 Fax : (022) 25798431 to 35 www.sgs.com

Member of the SGS Group



TEST REPORT

Report No. : GR:GL:6210020715

DATE : 15-12-06

JOE No. : 621107064

Control No.:6215021727

TESTS	PROTOCOL	RESULT
Tribromodiphenyl ether		ND(D.L.5ppm)
Tetrabromodiphenyl ether		ND(D.L.5ppm)
Pentabromodiphenyl ether		ND(D.L.5ppm)
Hexabromodiphenyl ether		ND(D.L.5ppm)
Heptabromodiphenyl ether		ND(D.L.5ppm)
Octabromodiphenyl ether		ND(D.L.5ppm)
Nonabromodiphenyl ether		ND(D.L.5ppm)
Decabromodiphenyl ether		ND(D.L.5ppm)
Remark: ND= Not Detected DL= Detection Limit		
Conclusion: When tested as specified, the submitted sample complies with the requirements of RoHS Consultation document on 2002/95/EC.		

***** End of Report *****

per pro SGS India Private Ltd.


Authorised Signatory