



TEST REPORT

Report No. : GR:GL:7210002120

DATE : 29/01/07

JOE No. : 721100563

Report Control No.:7215001425

SAMPLE NOT DRAWN BY LABORATORY

SAMPLE SUBMITTED AND IDENTIFIED BY SUPPLIER AS : HEAT RECOVERY WHEEL (SG)

COMPANY NAME DESICCANT ROTORS INTERNATIONAL PVT. LTD.
ADDRESS 100-101,UDYOG VIHAR-IV
CITY GURGAON-122015
SAMPLING METHOD N.A.
SAMPLE DESCRIPTION Heat Recovery Wheel (SG)
SAMPLE RECD ON 22-01-2007
TEST START DATE 22/01/07
TEST END DATE 29/01/07

Table with 5 columns: TESTS, PROTOCOL, RESULT, REQUIREMENT/LIMIT (MIN, MAX). Rows include Cadmium, Lead, Mercury, Hexavalent Chromium-(Cr-VI), Polybrominated Biphenyls (PBBs), and Polybrominated Diphenylethers (PBDEs).

This document is issued by the company subject to its general conditions of service printed overleaf or available on request and accessible at www.sgs.com. Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. Unless otherwise stated: (A) the results shown in this document refer only to the sample(s) tested and (B) such sample(s) are retained for 30 days only. This document cannot be reproduced except in full, without prior approval of the company. Any unauthorized alteration, forgery or falsification of the content or appearance of this report is unlawful and offenders may be prosecuted to the fullest extent of the law. The information stated in this report (or certificate) is derived from the results of inspection or testing procedures carried out in accordance with the instructions of our client, and/or our assessment of such results on the basis on any technical standards, trade custom or practice, or other circumstances which should in our professional opinion to be taken into account

SGS India Pvt. Ltd. Laboratory, 250, Udyog Vihar, Phase IV, Gurgaon - 122015, Haryana (India) Phone : +91-124-2399990 - 98 , Fax : 2399765.

Regd & Corp. Off : SGS House, 4B, A.S. Marg, Vikhroli (West), Mumbai-400083. Tel : (022) 25798421 to 28 Fax : (022) 25798431 to 35 www.sgs.com



TEST REPORT

Report No. : GR:GL:7210002120

DATE : 29/01/07

JOE No. : 721100563

Report Control No.:7215001425

TESTS	PROTOCOL	RESULT	REQUIREMENT/LIMIT	
			As per RoHS	
			MIN	MAX
Hexabromodiphenyl ether		ND(D.L.5ppm)		
Heptabromodiphenyl ether		ND(D.L.5ppm)		
Octabromodiphenyl ether		ND(D.L.5ppm)		
Nonabromodiphenyl ether		ND(D.L.5ppm)		
Decabromodiphenyl ether		ND(D.L.5ppm)		
Remarks: When tested as specified, the submitted Sample complies with RoHS Consultation Document on 2002/95/EC. ND - Not Detected DL - Detection Limit				

***** End of Report *****

per pro SGS India Private Ltd.


Authorised Signatory


TEST REPORT

Sample No.: GR:GL:7210002120

DATE : 29/01/07

JOE No. :721100563

Report no.: 7215001425



SGS Authenticate the Photo on original report only

****End of Report****

This Test Report is issued by the Company subject to its General Conditions of Service printed overleaf or available upon request and accessible at www.sgs.com. Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. The results shown in this test report refer only to the sample(s) tested unless otherwise stated and such sample(s) are retained for 30 days only unless otherwise stated. This Test Report cannot be reproduced, except in full, without prior written approval of the Company.

The information stated in this report (or Certificate) is derived from the results of inspection or testing procedures carried out in accordance with the instructions of our clients , and /or our assessment of such results on the basis of any technical standards , trade custom or practice , or other circumstances which should in our professional opinion be taken into account .

SGS India Pvt Ltd Laboratory Services, 250, Udyog Vihar, Phase IV, Gurgaon - 122015, Haryana (India) Phone : +91-124-2399990 - 98 , Fax : 2399765.

Regd & Corp. Off : SGS House, 4B, A.S. Marg, Vikhrolli (West), Mumbai-400083. Tel : (022) 25798421 to 28 Fax : (022) 25798431 to 35 www.sgs.com

Member of the SGS Group